

# FMCS Water Heater Control Wiring Specification

- Water heater controls must be installed on the outside of dwelling
- Use PVC or bakelite box without threaded hubs only
- Adequate side clearances, top clearance and height from ground must be followed
- **Electrical inspection required.**
- **Freeborn County, contact Dennis Anderson, 507-845-2711.**
- **Mower County, except cities of Austin, Lyle, Mapleview & Townships of Austin, Lansing & Lyle, contact Steve Roberts, 507-254-4272.**
- **Cities of Austin, Lyle, Lansing and Townships of Austin, Lansing & Lyle, contact Aaron Goslee, 507-440-1433.**

